



1 **EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 EC - Type Examination Certificate Number: **Baseefa03ATEX0443X**

4 Equipment or Protective System: **VANE ACTUATOR AND SPRING RETURN UNIT**

5 Manufacturer: **KINETROL LIMITED**

6 Address: **Trading Estate, Farnham, Surrey. GU9 9NU**

7 This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Baseefa (2001) Ltd. Notified body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. 02(CI)0343

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN13463-1:2001 EN13463-5:2003 Inherent Safety

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12 The marking of the equipment or protective system shall include the following :

(Ex) II 1GD cg 90°C Tamb -20°C to +80°C

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 0622

Project File No. 02/0343

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

Baseefa (2001) Ltd.

Health and Safety Laboratory Site, Harpur Hill,
Buxton, Derbyshire SK17 9JN
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216
e-mail info@baseefa2001.biz web site www.baseefa2001.biz
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,
Derbyshire, SK17 9BJ

R S SINCLAIR
DIRECTOR
On behalf of
Baseefa (2001) Ltd.

13

Schedule

14

Certificate Number Baseefa03ATEX0443X

15 Description of Equipment or Protective System

The Kinetrol Vane Actuator is used to open and close mechanical valves. The actuator is available in eleven sizes with output torques up to 1375 Nm at 7 Bar and up to 102° travel depending on the size of actuator. The operating temperature of the actuator is determined by surrounding atmosphere and the shaft and flange seals fitted. The actuator can be provided with male or female connection facilities for subsequent connection to valves.

The Actuator consists of a painted metallic fan shaped main case, which is in two halves. The two case halves are fixed together by several bolt and nut assemblies around the flanged edges of the case and the flanged edges are sealed with sealant. The case houses a two plate metallic vane complete with upper and lower shafts and bearings that pass through openings in the upper and lower case halves. The vane is fitted with non-metallic seals and expanders around its edges to provide a seal face between the vane and the case, and the shafts are also fitted with non-metallic seals to provide a seal between the shaft and the upper and lower openings in the case. The main case is fitted with two screws that enable adjustment of the vane movement at each end of its stroke for accurate seating of the associated valve.

The actuator is operated by clean air or by various gas mediums to suit customer requirements. The operating medium is forced into the sealed case via air ports that are positioned on either side of the vane. The air causes the vane to pivot on the shaft at speeds less than 1m/s, and this rotation of the shaft is used to operate a mechanical valve.

The Vane Actuator may be fitted with the following options:

Metallic Namur adaptor block, metallic ISO adaptor and coupler, metallic mounting bracket and coupling, and Spring Return Unit.

Spring Return Unit:

The spring return unit may be supplied fitted to the Vane Actuator, or supplied separately providing it is fitted with its own relevant certification labelling.

The spring return unit is available in nine sizes from ø58.8 x 23.2 deep up to ø258 x 136 deep. The operating temperature of the spring return unit is determined by the surrounding atmosphere and the shaft and flange seals fitted. The Spring Return Unit consists of a metallic case which comprises of an upper spring housing and metallic spring base plate, which are fixed together by several bolt and nut assemblies around the flanged edges of the case, and the flanged edges are sealed using an o-ring. Within the spring housing there is a grease covered clockwise or anticlockwise low stress clock type spring. The spring is anchored to a coupler, complete with o-rings, at the inside of the winding and is fixed at the outside of the winding by screw fixings within the wall of the spring housing. The coupler provides either a male or female connection, passing through an opening in the top of the spring housing and an opening in the bottom of the spring base plate. The lower part of the coupler is used for subsequent connection to the vane Actuator and the upper part of the coupler is connected to the appropriate device/mechanism. The spring return unit is sealed to the vane actuator using either a cork based gasket or sealant.

Variation 0.1

When the actuator and spring return units are fitted with alternative viton seals/o-rings then they may be marked as follows:

Ⓔ II 1GD cg 110°C Tamb -20°C to +100°C



16 Report Number

02(CI)0343

17 Special Conditions for Safe Use

1. The maximum rubbing speed of any component within the actuator and spring return unit must not exceed 1m/s.
2. The actuator shall not be operated with flammable gas/air mixtures.
3. Do not allow dust layers to build up on the apparatus.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

| Number | Issue | Date | Description |
|-------------|-------|----------|---|
| 98-250/A1 | G | 01/04/04 | Actuators and other mechanical ancillaries for use in category 1 explosive atmospheres. |
| 98-256/A1 | D | 01/04/04 | Spring return units for use in category 1 explosive atmospheres. |
| 99-033-4/A3 | G | 17/03/04 | ATEX actuator label category 1 (Viton) |
| 99-033-5/A3 | H | 17/03/04 | ATEX actuator label category 1 |
| 99-058/A3 | D | 01/04/04 | CE 0518 Label |



1 **SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 94/9/EC**

3 Supplementary EC - Type Examination Certificate Number: **Baseefa03ATEX0443X/1**

4 Equipment or Protective System: **VANE ACTUATOR AND SPRING RETURN UNIT**

5 Manufacturer: **KINETROL LIMITED**

6 Address: **Trading Estate, Farnham, Surrey, GU9 9NU**

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa03ATEX0443X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 Item 9 of the original Certificate is replaced by “Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 13463-1: 2009 EN 13463-5: 2011

except in respect of those requirements listed at item 18 of the Schedule.”

9 The marking of the equipment has changed from the original Certificate and shall include the following:

⊕ II 1GD c T90°C T_{amb} -20°C to +80°C

This certificate shall be held with the original certificate and may only be reproduced in its entirety, without any change, schedule included.



Baseefa Customer Reference No. **0622**

Project File No. **12/0622**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

Baseefa

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail info@baseefa.com web site www.baseefa.com
Baseefa is a trading name of Baseefa Ltd
Registered in England No. 4305578. Registered address as above.


P. R. S. SINCLAIR 
DIRECTOR
On behalf of
Baseefa



13

Schedule

14

Certificate Number Baseefa03ATEX0443X/1

15 Description of the variation to the Equipment or Protective System

Variation 1.1

To confirm that the equipment covered by this certificate has been reviewed against the requirements of EN 13463-1: 2009 and EN 13463-5: 2011 in respect of the differences from EN 13463-1: 2001 and EN 13463-5: 2003 and Inherent Safety (EN 13463-4), and the equipment has been assessed and is in compliance with the requirements of the latest standards.

Variation 1.2

When the Actuator and Spring Return Valve units are fitted with alternative viton seals/o-rings then the marking will change as follows:

⊕ II 1GD c T110°C T_{amb} -20°C to +100°C

16 Report Number

12(C)0622

17 Specific Conditions of Use

As previously listed.

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

19 Drawings and Documents

| Number | Issue | Date | Description |
|----------|-------|----------|---------------------------------|
| 99-033-4 | H | 06/08/12 | ATEX actuator label Cat 1 Viton |
| 99-033-5 | J | 06/08/12 | ATEX actuator label Cat 1 |

1 SUPPLEMENTARY EU - TYPE EXAMINATION CERTIFICATE

**2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 Supplementary EU - Type Examination Certificate Number: **Baseefa03ATEX0443X/2**

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **VANE ACTUATOR AND SPRING RETURN UNIT**

5 Manufacturer: **KINETROL LIMITED**

6 Address: **Trading Estate, Farnham, Surrey, GU9 9NU**

7 This supplementary certificate extends EC – Type Examination Certificate No. Baseefa03ATEX0443X to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that the product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.



9 Item 9 of the original Certificate is replaced by “Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN ISO 80079-36:2016 EN ISO 80079-37:2016



except in respect of those requirements listed at item 18 of the Schedule.”

12 The marking of the equipment has changed from the original Certificate and shall include the following:

Units fitted with standard seals/o-rings

 **II 1G Ex h IIC 90°C Ga**
 **II 1D Ex h IIIC T90°C Da**
-40°C ≤ Ta ≤ 80°C

Units fitted with Viton seals/o-rings

 **II 1G Ex h IIC 110°C Ga**
 **II 1D Ex h IIIC T110°C Da**
-20°C ≤ Ta ≤ 100°C

SGS Baseefa Customer Reference No. **0622**

Project File No. **19/0172**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.


SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR
TECHNICAL MANAGER
On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa03ATEX0443X/2

15 Description of the variation to the Product

Variation 2.1

To confirm that the equipment covered by this certificate has been reviewed against the requirements of EN ISO 80079-36:2016 and EN ISO 80079-37:2016 in respect to the differences of EN 13463-1:2009 and EN 13463-5: 2011. The equipment has been assessed and is in compliance with the requirements of the latest standards.

Variation 2.2

To limit the paint finishes applied to the Vane Actuator and Spring Return Unit casings to either Powder Epoxy Coated or PTFE Loaded Epoxy paints.

Variation 2.3

To change the lower ambient temperature range for Vane Actuator and Spring Return Units fitted with standard Nitrile/Silicon seals/o-rings from -20°C to -40°C.

16 Report Number

19(C)0172

17 Specific Conditions of Use

None additional to those listed previously

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

| Clause | Subject |
|--------|--------------------------------------|
| 1.2.3 | Enclosed structures to prevent leaks |
| 1.4.1 | External Effects |
| 1.4.2 | Aggressive Substances, etc |

19 Drawings and Documents

| Number | Issue | Date | Description |
|----------|-------|----------|---|
| 98-250 | J | 25.06.19 | Kinetrol Actuators And Other Mechanical Ancillaries For Use In Category 1 Explosive Atmospheres |
| 98-256 | F | 25.06.19 | Kinetrol Spring Return Units For Use In Category 1 Explosive Atmospheres |
| 99-033-4 | J | 12.06.19 | ATEX Actuator Label Cat 1 Viton |
| 99-033-5 | K | 12.06.19 | ATEX Actuator Label Cat 1 |