

Title: EU DECLARATION OF CONFORMITY - KINETROL LTD. (TD151-1) (Z)

APPROVED ELECTRICAL EQUIPMENT

Kinetrol declares under our sole responsibility that the products listed below conform to the relevant provisions of Directive 2014/34/EU. (ATEX directive on convergence of EU legislation for explosion proof equipment.)

Product	Notified Body	Conformity demonstrated with reference to following documentation	Compliance with essential Health & Safety requirements assessed by reference to following standards
*Universal Switchbox Type 003 Switch	Intertek Testing & Certification Ltd. Leatherhead Surrey KT22 7SB, UK	ITS 03ATEX31060 & ITS 03ATEX31060/1	EN 60079-0:2006 EN 60079-1:2007 EN 60079-7:2007
Universal Type 001 & 009 Switch		ITS 03ATEX21478X Issue 2	EN 60079-0:2012 EN 60079-11:2012
AP Positioner	Baseefa Ltd. Rockhead Business Park Standen Lane Buxton, Derbyshire SK17 9RZ, UK	Baseefa 02ATEX0197/1 Baseefa 02ATEX0197/2 Baseefa 02ATEX0197/3	EN 60079-0:2009 EN 60079-11:2007 EN 13463-1:2009
EL Positioner		Baseefa 03ATEX0098 Issue 5	EN 60079-0:2012 +A11:2013 EN 60079-11:2012
XLS Flameproof Limit Switch Box	SGS Fimko Oy Takomotie 8 FI-00380 Helsinki Finland	Baseefa07ATEX0085X Issue 2	EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-31:2014

Products above marked with “*” have been self assessed in report KTR137 Issue B to ensure compliance with later EN 60079 type standards.

Quality Assurance Notification No: SIRA 02ATEX M166 valid until 30th March 2023.
Other applicable directives: 06/42/EC, 14/30/EU.



R.C.Chapman
Engineering Manager
For & on behalf of Kinetrol Ltd.

Issue Z	Signed NKS	Date 17-05-21	KINETROL	Trading Estate Farnham Surrey GU9 9NU England	Doc.No. TD 151-1
Page 1 of 1					