

Title: DECLARATION OF CONFORMITY - KINETROL LTD. (TD151-1) (AA)

APPROVED ELECTRICAL EQUIPMENT

Kinetrol declares under our sole responsibility that the products listed below conform to the relevant provisions of Directive 2014/34/EU. (ATEX directive on convergence of EU legislation for explosion proof equipment.)

Product	Notified Body	Conformity demonstrated with reference to following documentation	Compliance with essential Health & Safety requirements assessed by reference to following standards
*Universal Type 003 Switch	Intertek Testing & Certification Ltd. Leatherhead Surrey KT22 7SB, UK	ITS 03ATEX31060 & ITS 03ATEX31060/1	EN 50014:1997 EN 50018:2000 EN 50019:1999
*Universal Type 001 & 009 Switch		ITS 03ATEX21478X Issue 2	EN 60079-0:2012 EN 60079-11:2012
*AP Positioner	SGS Fimko Oy Takomotie 8 FI-00380 Helsinki Finland	Baseefa 02ATEX0197/3	EN 60079-0:2009 EN 60079-11:2007 EN 13463-1:2009
*EL Positioner	SGS Fimko Oy Sarkiniementie 3 PO Box 30 FI-00211 Helsinki. Finland	Baseefa 03ATEX0098X Issue 5	EN 60079-0:2012 +A11:2013 EN 60079-11:2012
XLS Flameproof Limit Switch Box	SGS Fimko Oy Takomotie 8 FI-00380 Helsinki Finland	Baseefa07ATEX0085X Issue 2	EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-31:2014

Products above marked with '*' citing old standards have been checked to the requirements of the new standards as listed below (as applicable) and there were no differences affecting the latest technical knowledge for the products identified on this declaration.

Standards used in this evaluation include:

EN IEC 60079-0:2018, EN IEC 60079-1:2014, EN IEC 60079-7:2015,
EN 60079-11:2012, BS EN 60079-31:2014

Quality Assurance Notification No: SIRA 02ATEX M166 valid until 30th March 2023.

Other applicable directives: 06/42/EC, 14/30/EU.



R.C.Chapman
Engineering Manager
For & on behalf of Kinetrol Ltd.

Issue AA	Signed RCC	Date 13-12-22	KINETROL	Trading Estate Farnham Surrey GU9 9NU England	Doc.No. TD 151-1 Page 1 of 1
-------------	---------------	------------------	-----------------	--	---------------------------------